1. What is the maximum acceptable concentration?

According to Canada Health Guidelines, the acceptable level is 10 micrograms per litre.

2. I have been drinking the water over the summer months. Should I be worried?

If concerned, please contact your family physician.

3. When was the last time the water was tested?

In the past, tests have been performed in specific locations across campus. The most recent testing was completed October 2013. The most recent test to detect lead was conducted in November 2012.

4. How does this result impact food service on campus?

All food outlets will comply with the 60 second run recommendation.

5. Will bottled be provided?

Not at this time.

6. When will updated results be available?

Additional testing is scheduled for September. The campus will be updated as soon as results become available. Results typically take two to three weeks.

7. Is my shower safe?

Yes. The water is acceptable for regular general use, including hand-washing, laundry, etc.

It is recommended to run the tap water at least 60 seconds before brushing your teeth.